FIRE SAFETY INSPECTION REPORT

Gridley Fire Department
685 Kentucky Street
Gridley, CA. 95948 (530) 846-1000

Business Address: _____ Inspection Date:_____

Business Name:_____ Business Phone:_____

Owner/Property Management: _____ Phone:_____

Address:_____ City:_____ Zip:_____ AP#___- ___-___

N0	✓	CORRECTIONS REQUIRED	NO.	LOCATION / REMARKS	CLEARED
		ACCESS			
1		Maintain fire lane free of obstructions.			/ /
2		Provide fire lane identification.			
3		Provide address numbers/building I.D. visible from street.			
4		Provide approved key box/lock/switch and/or keys for fire dept. access.			
		EXITING			/ /
5		Remove obstructions at exits, doors, aisles, corridors, stairways, etc.			
6		Exit door to open without a key or any special knowledge/effort.			
7		Provide sign over main exit door - "This door to remain unlocked during business hours".			
8		Repair non-operable exit door hardware.			/ /
9		Remove obstructions from door required to be closed.			
10		Remove locks/latches from doors with panic hardware.			
11		Remove storage from unprotected stairway.			
12		Provide/maintain exit sign/emergency lighting.			/ /
		FIRE EXTINGUISHERS			
13		Have fire extinguisher(s) serviced and tagged.			
14		Provide/mount fire extinguisher as indicated.			
15		Provide clear access to fire extinguisher.			/ /
16		Post a sign indicating fire extinguisher location.			
		FIRE PROTECTION EQUIPMENT			
17		Maintain, repair, paint, inspect, and/or test sprinkler/standpipe system/hydrant/FDC/PIV.			
18		Maintain 3 ft. minimum clearance for access/use of fire appliances/equipment.			/ /
19		Secure all system control valves in the open position.			
20		Replace damaged/painted/missing sprinkler heads/FDC caps.			
21		Provide 5-year certification test for sprinkler/standpipe system.			
22		Provide sprinkler coverage in unprotected areas.			/ /
23		Provide spare sprinkler heads (min. 6) and/or compatible wrench.			
24		Hood and duct extinguishing system to be serviced and tagged every 6 mo.			
25		Remove grease from hood, duct, and filters. (KEEP CLEAN)			/ /
		FIRE ALARM SYSTEMS			
26		Maintain, repair, inspect, and/or test fire alarm system.			
27		Provide/maintain operable smoke alarms in each dwelling unit.			
		FIRE SEPARATIONS			
28		Repair holes in required fire resistive construction.			/ /
29		Provide/repair self or automatic closing fire rated assemblies.			
30		Keep attic access and scuttle openings closed.			
		ELECTRICAL			
31		Discontinue use of extension cords.			
32		Install permanent wiring for fixed and stationary appliances.			
33		Provide cover plates for all junction boxes. Provide spacers for electrical panel.			
34		Remove exposed wiring or protect in approved conduit.			
35		Provide a 30-inch clear space to and in front of electrical panel.			
36		Maintain wiring in good condition and protect from damage.			
		FLAMMABLE LIQUIDS COMPRESSED GASES			
37		Provide a flammable liquid storage cabinet or reduce storage to 10 gallons or less.			
38		Remove all flammable liquids not used for maintenance purposes.			
39		Store flammable liquids away from exits, stairs, or corridors.			
40		Clean up spilled flammable liquid.			
41		Replace lids on all flammable liquid storage containers not in immediate use.			
42		Remove all fueled vehicles from dwelling units.			
43		Secure compressed gas cylinders. Identify product name.			
		STORAGE HOUSEKEEPING			
44		Arrange storage in an orderly manner to provide access/egress.			
45		Remove combustible storage from boiler, mechanical, and electrical room.			
46		Reduce storage to 24 inches below ceiling or 18 inches below sprinkler heads.			
47		Provide metal or approved non-combustible trash container with lid.			
48		Remove lint/debris from behind washers and dryers.			
49		Remove waste/rubbish materials from the premises.			
50		Keep dumpsters 5 feet away from combustible walls, eaves, or openings.			
51		Provide minimum 30-foot clearance between building and combustible vegetation.			
		MISCELLANEOUS			
52		Other violations and comments.			
NO VIOLATIONS NOTED THIS DATE - THANK YOU FOR BEING FIRE SAFE!					

RE-INSPECTION DATES		INSPECTOR
1st	/ /	
2nd	/ /	
Refer to FPB	/ /	
District Attorney	/ /	
Final Clearance	/ /	
Occupancy Class:		☐ Check Pre-Fire Plan for accuracy.

B Y O R D E R O F T H E F I R E C H I E F

You are hereby notified to correct all violations immediately or show cause why you should not be required to do so. A re-inspection will be conducted on _____. Willful failure to comply with this notice is a misdemeanor. Violations that are not corrected immediately and/or remain after the re-inspection may be processed as a criminal offense. Thank you for your assistance and cooperation in minimizing the fire and life loss in your community.

Signature of Recipient: _____

☐ Owner ☐ Manager ☐ Employee ☐ Other_____

Inspecting Officer: _____

FPB: _____ Company: _____ ***Page*_____ *of* _____**

Distribution: White – to Owner/Occupant Red – Prevention Office FileRev. 8/7/06